

To: Way, Steven[way.steven@epa.gov]
From: Matt Francis
Sent: Thur 9/10/2015 3:07:34 AM
Subject: RE: Pipeline questions

See email fwd:Gold King. In it APTEC provides Calc saying flow meets requirements.

Sent via the Samsung Galaxy Note® 3, an AT&T 4G LTE smartphone

----- Original message -----

From: "Way, Steven" <way.steven@epa.gov>
Date: 09/09/2015 8:57 PM (GMT-07:00)
To: Matt Francis <m.francis@erllc.com>
Subject: Re: Pipeline questions

I am not seeing the APTec "disagreement "

What are they proposing?

Sent from my iPhone

> On Sep 9, 2015, at 7:16 PM, Matt Francis <m.francis@erllc.com> wrote:

>

> Looks like we have a disagreement between START review and what APTec calculated. Do we go for a tie-breaker, or just up size to 8" or 10" and not worry about it? Dual 6"?

>

>

>

> Sent via the Samsung Galaxy Note® 3, an AT&T 4G LTE smartphone

>

>

> ----- Original message -----

> From: "Petri, Elliott" <Elliott.Petri@WestonSolutions.com>

> Date: 09/09/2015 1:59 PM (GMT-07:00)

> To: "Way, Steven" <way.steven@epa.gov>, Matt Francis <m.francis@erllc.com>, "Myers, Craig" <Myers.Craig@epa.gov>

> Subject: RE: Pipeline questions

>

> Steve,

> I spoke with Dave and he said that the response below is a conservative estimate without doing a full design with proper profiles, from the email traffic it looks like APTec will be calculating flows as well.

>

> Dave offered to get on a conference call with us to clarify any questions you have for him. Below is the response he gave to your questions Steve:

>

> Elliot,

>

> Yes, that was a typo. I meant to say 10 fps. Here is the spreadsheet calculation for gravity flow. It says in the 8% 6-inch section will flow full at about 10 fps for about 500 gpm. These numbers are only estimates without a full design. If there are any high spots in the pipe which could trap air pockets it will greatly affect the flowrate. I emphasize we need air valves at those points. My gut is with air valves I

wouldn't count on much over 500 gpm.

>

> Thanks,

> Dave

>

> Let me know if you would like to arrange a call (if so who needs to be invited) or have any other questions.

>

> Thanks,

> Elliott

>

>

> Elliott Petri, PE

> Weston Solutions, Inc.

> 1435 Garrison St, Ste 100

> Lakewood, CO 80215

> Ph: 303-729-6156

> Cell: 719-216-2754

> Fax: 303-729-6101

>

> From: Way, Steven [mailto:way.steven@epa.gov]

> Sent: Wednesday, September 09, 2015 10:49 AM

> To: Matt Francis <m.francis@erllc.com>; Petri, Elliott <Elliott.Petri@WestonSolutions.com>; Myers, Craig <Myers.Craig@epa.gov>

> Subject: RE: Pipeline questions

>

> Elliott,

>

> Can you please provide information on Dave below (assume that he's with Weston) and is piping his specialty.

>

> He refers to 120 ft/s below and I assume that's a typo, but what is the number he was referring to. The question that I have is what is the capacity of the 6 inch line between the bottom of the steep slope (R n B laydown pad) and the run to Gladstone ? We need to make sure that the pipe is adequately sized with on 6 inch pipe or if not what size.

>

> Thank you,

> Steve

>

> Steven Way

> Federal On-Scene Coordinator

> Emergency Response Unit

> US EPA - Region 8

> 1595 Wynkoop Street

> Denver, CO 80202

>

> Office: 303-312-6723

>

> From: Matt Francis [mailto:m.francis@erllc.com]

> Sent: Tuesday, September 08, 2015 3:29 PM

> To: Petri, Elliott; Myers, Craig; Way, Steven

> Subject: RE: Pipeline questions

>

> Thanks Elliott, the pressures identified are what I needed to justify the DR7 upgrade. I've got enough now to make the case, just need confirmation of what configuration is wanted to get APTec started.

>

> Steve – the cost of support for HW is estimated at \$47K for a single line of each segment. That does not include the cost of mobilization of additional personnel to avoid disruption with other work. The price difference is \$65K, so there is a \$15-20K premium for using APTec that covers a more thorough design including safety factor of SDR7 pipe at the pressure point and a better demonstrated understanding of the project as presented in their proposal. APTec visited the site twice and the HW engineer has not seen it, making me more comfortable that APTec has fully covered anticipated costs. It seems from the technical review performed by START and EPA that the reviewers are more comfortable with APTec doing this work, and I believe it can be justified from a procurement point of view. Let me know if you concur and what configuration you would like.

> Thanks

> Matt

>

> From: Petri, Elliott [mailto:Elliott.Petri@WestonSolutions.com]

> Sent: Tuesday, September 08, 2015 10:34 AM

> To: Matt Francis <m.francis@erllc.com<mailto:m.francis@erllc.com>>; Craig Myers

<Myers.Craig@epa.gov<mailto:Myers.Craig@epa.gov>>; Steven Way

<Way.Steven@epa.gov<mailto:Way.Steven@epa.gov>>

> Subject: Fwd: Pipeline questions

>

> Hi Matt, Craig and Steve,

> I asked my reviewer to estimate max flow in a 6" pipe and the DR7 pipe, please see the exchange below. It requires more detail than I have him for exact calcs, but it looks like APT met the 1000gpm design criteria.

>

> Thanks,

> Elliott

>

> Elliott Petri, PE

> Weston Solutions, Inc.

> 1435 Garrison St, Ste 100

> Lakewood, CO 80215

> Ph: 303-729-6156

> Cell: 719-216-2754

> Fax: 303-729-6101

>

> Sent from a tiny phone screen, most likely with sun glare. Please excuse typos!

> -----

>

> Elliot,

>

>

>

> From what you have described the total drop on the pipe is around 550 feet. This means if the pipe was full because the valves were shut on the bottom the static head at the bottom of the pipe would be about 240 psi. HDPE DR 7 pipe is rated at 267 psi so it can hold the static pressure. This does not account for water hammer which may increase the pressure substantially. HDPE DR 11 is rated at 160 psi. As for the capacity, the ID of 6-inch HDPE DR 7 is 4.619" so if water was flowing at 120 ft/sec, the pipe would carry about 500 gpm and at 20 ft/sec 1000 gpm. It's really hard to calculate a max capacity for the pipe based on the information we have, but 20 ft/sec would be a good guess as the max velocity in the pipe. Call if you have questions.

>

>

>

> Thanks,

>

> Dave

>
>
>
> From: Elliott
>
>
>
> The slope at the worst is 35% over 850If,....um the slope at the top is extremely rough (run over drop)
~500/50, the bottom more like 8% for 2500 ft. There are some variable changes but from a quick snap
shot of my mind this is a really rough go.
>
>
>
> Thanks,
>
> Elliott
>
>
>
> Elliott Petri, PE
>
> Weston Solutions, Inc.
>
> 1435 Garrison St, Ste 100
>
> Lakewood, CO 80215
>
> Ph: 303-729-6156
>
> Cell: 719-216-2754
>
> Fax: 303-729-6101
>
>
>
> Sent from a tiny phone screen, most likely with sun glare. Please excuse typos!
>
>
>
> "Dave" wrote:
>
> What can you give me for details on the pipe alignment? Slope?
>
>
>
>
>
>
> From: Petri, Elliott
> Sent: Tuesday, September 08, 2015 7:21 AM
> To: Dave
> Subject: Pipeline questions
>
>
>
> Hi Dave,

>
> Can you calculate the max capacity of the GKM 6" line APTEC proposed and justify the DR7 pipe the
proposed as well...they want to award today.
>
>
>
> Thanks,
>
> Elliott
>
>
>
> Elliott Petri, PE
>
> Weston Solutions, Inc.
>
> 1435 Garrison St, Ste 100
>
> Lakewood, CO 80215
>
> Ph: 303-729-6156
>
> Cell: 719-216-2754
>
> Fax: 303-729-6101
>
>
>
> Sent from a tiny phone screen, most likely with sun glare. Please excuse typos!
>
> CONFIDENTIALITY: This email and attachments may contain information which is confidential and
proprietary. Disclosure or use of any such confidential or proprietary information without the written
permission of Weston Solutions, Inc. is strictly prohibited. If you received this email in error, please notify
the sender by return e-mail and delete this email from your system. Thank you.
>
>
> Confidentiality Warning: This e-mail and any attachments contain information intended only for the use
of the individual or entity named above. If the reader of this e-mail is not the intended recipient or the
employee or agent responsible for delivering it to the intended recipient, any dissemination, publication or
copying of this e-mail is strictly prohibited. Although this email has been scanned for malware, the sender
does not accept any responsibility for any loss, disruption or damage to your data or computer system
that may occur while using data contained in, or transmitted with, this e-mail. If you have received this e-
mail in error, please immediately notify by return e-mail. Thank you.
>
> CONFIDENTIALITY: This email and attachments may contain information which is confidential and
proprietary. Disclosure or use of any such confidential or proprietary information without the written
permission of Weston Solutions, Inc. is strictly prohibited. If you received this email in error, please notify
the sender by return e-mail and delete this email from your system. Thank you.